

D	SMITH® JAY R. SMITH MFG. CO.® MEMBER OF MORRIS GROUP INTERNATIONAL POST OFFICE BOX 3237 MONTGOMERY, ALABAMA 36109-0237 (USA) TEL: 334-277-8520 FAX: 888-377-7818 www.jrsmith.com MEMBER OF: NSF					LOCATION 																																									
	EXPOSED 1/4 TURN NON-FREEZE "TWIN TEMP" WALL HYDRANT																																														
5660QT (-H-WH) 5661QT (-H-WH)						Polished Brass Face Plate Wheel Handle Wall Thickness 1 1/2 (38) 3/4 (19) Male NPT Inlet 1/2 (13) Female NPT Inlet Vacuum Breaker w/ 3/4(19) Hose Connection																																									
	Installer is responsible for providing a 100% watertight positive seal at the hydrant to wall interface. Seal all the flange with an appropriate sealant recommended by a sealant manufacturer. NOTE: Jay R. Smith does not warrant the performance or life expectancy of the sealant material. Fig. 5660QT..... 1/2"(13) FEMALE & 3/4"(19) MALE INLET Fig. 5661QT..... 1"(25) MALE INLET																																														
REGULARLY FURNISHED: Bronze Quarter Turn Non-Freeze "Twin-Temp" Hydrant with 3/4"(19) Hose Connection, "T" Handle Key. Inlet Size Furnished as Indicated by Figure Number Selected. VARIATIONS: ☐ Adjustable Wall Clamp -WC ☐ Wheel Handle -WH ☐ Vacuum Breaker Self Draining Type -H OPTIONAL MATERIALS: ☐ Nickel Bronze Face -NB ☐ Chrome Plated Face -CP ☐ Rough Bronze Face -RB																																															
NOTES: - Recommended wall opening 6"(150) x 6"(150). - When ordering, specify wall thickness in 2"(51) increments as follows: 6(150), 8(205), 10(255), 12(305), 14(355), 16(405), 18(455), 20(510), 22(560) or 24(610). When wall clamp -WC is desired, increase wall thickness dimension by 2"(51). - For hose to drain and provide non-freeze protection the hose MUST be removed from the hose connection. - All Jay R. Smith hydrants are manufactured with "NO-LEAD" brazing rings and USDA approved lubricants. - The AB100, AB1953, California Lead Law, and NSF/ANSI Standard 61 - Drinking Water System Components are not applicable to Jay R. Smith hydrants as they do not convey/dispense water for human consumption through drinking or cooking. - Dimensions shown in parentheses are in millimeters. FOR IRRIGATION PURPOSES ONLY.																																															
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 10%;">D</td> <td style="width: 10%;">8-4-23</td> <td style="width: 30%;">Removed Function</td> <td style="width: 10%;">HS</td> <td style="width: 10%;">CL</td> <td style="width: 10%;">WEIGHT</td> <td style="width: 10%;">VOLUME</td> <td style="width: 20%;">FIGURE NUMBER</td> </tr> <tr> <td>C</td> <td>3-22-23</td> <td>Revised Note 5</td> <td>KK</td> <td>JT</td> <td>POUNDS</td> <td>CUBIC FEET</td> <td rowspan="3" style="text-align: center; vertical-align: middle;"> 5660QT (-H-WH) 5661QT (-H-WH) </td> </tr> <tr> <td>B</td> <td>4-5-18</td> <td>Added Notes</td> <td>TBW</td> <td>BW</td> <td></td> <td></td> </tr> <tr> <td>A</td> <td>2-4-13</td> <td>Revised Notes</td> <td>TBW</td> <td>CL</td> <td></td> <td></td> </tr> <tr> <td>REV.</td> <td>DATE</td> <td>DESCRIPTION</td> <td>BY</td> <td>CKD. BY</td> <td></td> <td></td> <td></td> </tr> </table>										D	8-4-23	Removed Function	HS	CL	WEIGHT	VOLUME	FIGURE NUMBER	C	3-22-23	Revised Note 5	KK	JT	POUNDS	CUBIC FEET	5660QT (-H-WH) 5661QT (-H-WH)	B	4-5-18	Added Notes	TBW	BW			A	2-4-13	Revised Notes	TBW	CL			REV.	DATE	DESCRIPTION	BY	CKD. BY			
D	8-4-23	Removed Function	HS	CL	WEIGHT	VOLUME	FIGURE NUMBER																																								
C	3-22-23	Revised Note 5	KK	JT	POUNDS	CUBIC FEET	5660QT (-H-WH) 5661QT (-H-WH)																																								
B	4-5-18	Added Notes	TBW	BW																																											
A	2-4-13	Revised Notes	TBW	CL																																											
REV.	DATE	DESCRIPTION	BY	CKD. BY																																											



WARNING: Cancer and Reproductive Harm - www.P65Warnings.ca.gov