

L	JAY R. SMITH MFG. CO. MEMBER OF MORRIS GROUP INTERNATIONAL POST OFFICE BOX 3237 MONTGOMERY, ALABAMA 36109-0237 (USA) TEL: 334-277-8520 FAX: 888-377-7818 www.jrsmith.com MEMBER OF: LOCATION																																										
	SPECIAL PURPOSE DRAINS STAINLESS STEEL - CARBON STEEL																																										
DRAWING NUMBER	SIZE A SCALE: NONE DATE: 11-12-84 APPROVED BY: T.D. CHECKED BY: VGd DRAWN BY: CMB																																										
DRAWING NUMBER	HEAVY DUTY DRAIN WITH FREE STANDING SEDIMENT BUCKET Free Area 42 SQ IN (271) SQ CM Side View Front View A (Pipe Size) = 02(50), 03(75), 04(100), 05(125) or 06(150) Fig. 9755BW . . . BUTT WELD OUTLET (Schedule 40 Regularly Furnished) Fig. 9734BW NO-HUB OUTLET																																										
WE CAN ASSUME NO RESPONSIBILITY FOR USE OF SUPERSEDED OR VOID DATA	REGULARLY FURNISHED: CF8 (Equivalent to Type 304) Rough Finish Stainless Steel Body with Sediment Bucket and Heavy Duty Loose Set Polished Bronze Grate. VARIATIONS: ☐ 4(100) or 6"(150) Dia. Funnel (Specify Fig. 9703) ☐ 8 3/4(220) x 3 3/4"(95) Funnel (Specify Fig. 9704) ☐ 90° Side Outlet (Specify Fig. 9759) ☐ Flashing Clamp with Seepage Holes -C ☐ Seepage Holes -WSH ☐ BW Butt Weld Outlet (Specify Schedule -S05, -S10, -S40 or -S80) OPTIONAL MATERIALS: ☐ A-27 Carbon Steel -A27 ☐ CF8 (Equivalent to Type 304) Stainless Steel Grate -SSG ☐ CF8M (Equivalent to Type 316) Stainless Steel Grate -316 ☐ Nickel Bronze Grate -NB ☐ Stainless Steel Satin Finished Grate -SFG Design Pressures and Temperatures - With proper outlet connection, shall be watertight up to 10 ft. of water column (4.34 psig). - When exposed to effluent appropriate for drain material, the drain shall withstand effluent temperatures of 180 degrees F at ambient pressure. NOTE: Dimensions shown in parentheses are in millimeters.																																										
DIMENSIONS ARE SUBJECT TO MANUFACTURERS TOLERANCE AND CHANGE WITHOUT NOTICE	<table border="1" style="width: 100%; border-collapse: collapse; font-size: 8px;"> <tr> <td style="width: 10%;">L</td> <td style="width: 15%;">10-16-24</td> <td style="width: 30%;">Revised Variations</td> <td style="width: 10%;">HS</td> <td style="width: 10%;">JT</td> <td style="width: 15%;">WEIGHT POUNDS</td> <td style="width: 15%;">VOLUME CUBIC FEET</td> <td style="width: 15%;">FIGURE NUMBER</td> </tr> <tr> <td>K</td> <td>8-28-23</td> <td>Removed Function</td> <td>HS</td> <td>CL</td> <td></td> <td></td> <td rowspan="3" style="text-align: center; font-size: 24px; font-weight: bold;">9755</td> </tr> <tr> <td>J</td> <td>2-16-22</td> <td>Added NO-HUB Outlet Option</td> <td>KK</td> <td>CL</td> <td></td> <td></td> </tr> <tr> <td>H</td> <td>10-18-11</td> <td>Added Note</td> <td>TBW</td> <td>CL</td> <td></td> <td></td> </tr> <tr> <td>REV.</td> <td>DATE</td> <td>DESCRIPTION</td> <td>BY</td> <td>CKD. BY</td> <td></td> <td></td> <td></td> </tr> </table>					L	10-16-24	Revised Variations	HS	JT	WEIGHT POUNDS	VOLUME CUBIC FEET	FIGURE NUMBER	K	8-28-23	Removed Function	HS	CL			9755	J	2-16-22	Added NO-HUB Outlet Option	KK	CL			H	10-18-11	Added Note	TBW	CL			REV.	DATE	DESCRIPTION	BY	CKD. BY			
L	10-16-24	Revised Variations	HS	JT	WEIGHT POUNDS	VOLUME CUBIC FEET	FIGURE NUMBER																																				
K	8-28-23	Removed Function	HS	CL			9755																																				
J	2-16-22	Added NO-HUB Outlet Option	KK	CL																																							
H	10-18-11	Added Note	TBW	CL																																							
REV.	DATE	DESCRIPTION	BY	CKD. BY																																							



WARNING: Cancer and Reproductive Harm - www.P65Warnings.ca.gov